



Government Of West Bengal
Office Of The Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services
6, Diamond Harbour Road, Silpara, Kol-700008

Memo no.: IND/WB/FES/20182019/47879

Date: 07-09-2023

From:

Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services

To: ST MONTFORT'S SENIOR SECONDARY SCHOOL

Balarampur, P.O.-Madarat, P.S.- Baruipur, kolkata Pin-743610

Sub: Renewal Fire Safety Certificate for an existing construction of G+I storied under group Educational building, in the name of ST MONTFORT'S SENIOR SECONDARY SCHOOL at the premises no.- Balarampur, P.O.-Madarat, P.S.- Baruipur, kolkata Pin-743610

This is in reference to your application no. 0125191231200274 dated 19-08-2023 regarding the Renewal Fire Safety Certificate for an existing construction of G+I storied under group Educational building, in the name of ST MONTFORT'S SENIOR SECONDARY SCHOOL at the premises no.- Balarampur, P.O.-Madarat, P.S.- Baruipur, kolkata Pin-743610

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
- Entrances / Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
- The Interior finish decoration of building shall be made with low flame spread material conforming to the I.S. Specification.
- To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
- Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
- A fire control room including a closed-circuit TV system shall have to be installed which observe all the floors of the building.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191231200274.

Page : 1

- g. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
- n. The employees and security staff shall be conversant with installed firefighting equipment's of the building and to operate in the event of fire and testing.
- i. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- j. crew of trained Firemen shall be maintained round the clock for fire safety of the building.
- k. First Aid firefighting system shall be provided as per I.S. specifications.
- l. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
- m. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- n. Periodical flashing of water in the Hydrants Pipe lines shall be made to maintain the efficient working performance of above-mentioned system.
- o. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
- p. This Renewal of Fire Safety Certificate is valid for three years and has to be renewed every three years from the date of issue of this certificate.
- q. The Fire Safety Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Signature valid

Digitally signed by TARUN
KUMAR DUTTA
Date: 2023.09.07 11:54:23 IST

Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services

Memo No.: INDI/WB/FES/20182491/1870


Principal
St. Montfort's Sr. Sec. School
Balarampur, P.O.- Madarat
P.S.- Baruipur, Pin- 743610, W.B.